

Result Summary Report

Program: Drinking Water Monitoring Program
Date Range: 31-12-2023 - 30-11-2024
Water Utility:
Supply System: Yenda GT02

Barcode: All
Analysis Type: All
Characteristics: All
Sample Types: All

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	48	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	1.6840	1.6400	0.4038	0.98	3	48	0	2.3	1.05	100.00
	pH	6.5 - 8.5		7.5473	7.5200	0.1596	7.25	7.93	48	0	7.83	7.3	100.00
	Temperature	30.0000	C	18.6583	18.7000	4.4600	11.8	25.8	48	0	24.9	11.9	100.00
	Total Chlorine	5.0000	mg/L	1.8721	1.8550	0.5323	0.25	3.2	48	0	2.73	1.09	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	48	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2471	0.2050	0.2734	0.09	2.06	48	0	0.32	0.11	100.00